



Tom Barrett  
Mayor

Bevan K. Baker, FACHE  
Commissioner of Health

Joe'Mar Hooper, MPA  
Health Operations Administrator

www.milwaukee.gov/health

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653 phone (414) 286-3521 fax (414) 286-5990

## Routine Food Reinspection #2

RH Companies LLC  
King's Greentree Amoco Gas N Mart  
6829 N 76th St  
Milwaukee, WI

2/25/2015

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

**Fee Amount:**  
**\$213.00**

### CDC Risk Code Factor Violation(s)

Code Number	Description of Violation	Correct By
CDC Risk Violation(s):	0	

### Good Retail Practice Violations(s)

Code Number	Description of Violation	Correct By
5-103.11	No hot or cold water available at the warewashing sinks. Restore hot and cold water. Provide an adequate water supply. Discontinue processing until water is restored and proper warewashing occurs.	3/4/2015

Good Practice Violation(s): 1

Total Violations: 1

### Notes:

Water is now restored to all the faucets and the sinks do drain, but now the pipe on the sinks are broken or loose and the water now drains on the floor. Showed employee at the time. Fee assessed. klj

On 2/25/2015, I served these orders upon RH Companies LLC by leaving this report with

Inspector Signature (Inspector ID:84)

Est. # 824051

Operator Signature